

ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ, ਉਪ ਮੰਡਲ ਨੰਬਰ 1, ਬਠਿੰਡਾ
424, ਮਿੰਨੀ ਸਕੱਤਰੇਤ, ਬਠਿੰਡਾ, email - sdehtidwss@gmail.com

SAFE DRINKING WATER AND SANITATION HYGIENE CERTIFICATE

No. 1216

Dated: 29-5-25

In this reference to PKS International School, Bathinda-Malout Road, Balluana (Bathinda) Ref. No. PKS/Gen/2025/1118 Dated 12-05-2025. An Inspection team headed by Sh. Harsh Choudhary (J.E.) under this Sub Division inspected PKS International School, Bathinda-Malout Road, Balluana (Bathinda) on Dated 15-05-2025. As per the water sample report received from District Water Testing Laboratory Bathinda vide Letter No. DWTL/BTI/2526/00054 Dated 08-05-2025. It is certified that PKS International School, Bathinda-Malout Road, Balluana (Bathinda) has safe drinking and sanitation facility as per the norms prescribed by department of Water Supply & Sanitation Punjab.

The above said certificate is valid for 1 year with effect from 08-05-2025 to 07-05-2026.

Sub Divisional Engineer,
Water Supply & Sanitation,
Sub Division No.1, Bathinda.

To

The Principal,
PKS International School,
Bathinda-Malout Road, Balluana,
Bathinda.

M. Singh

Head Mistress
P.K.S. International School
Balluana.

P. K. S. INTERNATIONAL SCHOOL

Chairman/President/Secretary

DISTRICT WATER TESTING LABORATORY, BATHINDA

Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

TEST REPORT

Name & Address of Customer :		Customer Reference No.	No. : PKS/GEN/2025/1117 Dated : 05/05/2025
Head Mistress		Sample Submitted by	Sh. Mohinder Singh
P.K.S International School Balluana , Bathinda		Date of Sample Receipt	05/05/2025
		Analysis Starting Date	06/05/2025
		Analysis completion Date	07/05/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC12834250000247F	Sample Type :	Water
Test Report No.:	DWTL/BI/2526/00054	Date of Issue :	08/05/2025
Registration no.:	DWTL/BI/REG2526/00130	Condition of Sample :	Unsealed
Collection Point:	NA	Quantity/Type of Bottle:	1000 ml / NA
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Water Sample from P.K.S International School. Balluana , Bathinda / NA
Village :	Balluana	Habitation :	Balluana
Block:	Bathinda	District :	Bathinda
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.78	6.5-8.5	No Relaxation	—	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	BDL	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 8 - 2023)
5	TDS	51	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	24	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	44	200	600	mg/l	IS 3025 (Part 21- 2009)IRA 2023) EDTA Method
9	Calcium(Ca)	9.6	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	4.8	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg-2.8 By Calculation Method
11	Chloride(Cl)	13.9	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition:

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = Milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
5. Temperature condition limit: 25-5°C and Humidity condition limit: 50-80%

Reviewed and Approved By

[Signature]

Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Bathinda

[Signature]
Head Mistress
P.K.S. International School
Balluana.

P. K. S. INTERNATIONAL SCHOOL
[Signature]
Chairman/President/Secretary